

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3774-0610:119 Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Dorma Door Controls, PO Box AC, Reamstown, PA 17567-0411
Contact: Rick Loose (717) 336-3881 Fax (717) 336-2106

DESIGN: Models EML-1011, EML-1012, EML-1021, EML-1022, EML-2071, EML-2072, EML-3085, EML-3086, EMSL-2061, EMSL-2062 and EMSL-2766 electric exit locks. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12 or 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as auxiliary locking device for fire-rated and non fire-rated doors to prevent un-wanted entry and unauthorized exit when installed in accordance with the California Building Code, Section 1003.3.1.10 Special egress-control devices. Authority having jurisdiction shall be consulted prior to installation.

XLF: 3774-0324:100

07-06-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 15, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager